

SAMPLE- SPECIFICATIONS ON DRAWINGS

©2009 Conspectus, Inc.

Specifications, Quality Assurance, Inspections & Investigations for Your Construction Projects

2231 ROUTE 50 | P.O. BOX 248 | TUCKAHOE, NJ 08250 | p: 609.628.2390 | f: 609.628.2393

6305 DEEP CREEK DRIVE | PROSPECT, KY 40059 | p: 502.228.9370

www.conspectusinc.com

SUBMITTALS

Upon Request from the Architect, submit product data and samples on manufacturers as listed in the specifications, or as approved by Architect.

MANUFACTURER'S LISTING

Submit a complete list, by specification article name, of all manufacturers and product types provided. If the Contractor makes a substitution, the submitted manufacturer's product data and samples must be approved by the Architect.

GYPSUM BOARD ASSEMBLIES

Manufacturers: United States Gypsum Company, National Gypsum, Georgia Pacific, Lafarge North America.
Gypsum Board Materials: ASTM C1396/C1396M. Thickness and types indicated, ends square cut, tapered edges.
Accessories: Edge Trim: U shaped exposed reveal bead, as recommended by gypsum board manufacturer.
Joint Materials: Reinforcing tape, joint compound and water; glass coated fiber tape for backing board.
Fasteners: ASTM C1002 Type S12 hardened screws for gypsum board and corner beads.
Adhesive: As recommended by gypsum board manufacturer.
Install gypsum board over wood studs and joists, walls and ceilings in accordance with manufacturer's instructions and as detailed.

CERAMIC TILE

Ceramic Tile Manufacturers: American Olean, Dal Tile, or Crossville Ceramics, Summitville Tile.
Ceramic Tile Materials: Floor tile ANSI A137.1; wall tile ANSI A137.1; sizes as indicated. Colors and patterns selected by Owner.
Mortar and Grout Manufacturers: Mapei Corporation. Custom Building Products or Laticrete International Inc.
Mortar and Grout Materials: Mortar Materials: ANSI A118.4; Portland cement, sand, latex additive, and water.
Grout: Cementitious type with latex additive.
Install tile, mortar and grout in accordance with TCNA Handbook for Ceramic Tile Installation; and tile manufacturer's instructions.

RESILIENT TILE FLOORING AND BASE

Manufacturers: Armstrong World Industries, Inc., Azrock by Tarkett, or Mannington.
Submit color and finish samples for VCT and vinyl base.
Vinyl Composition Tile: ASTM F1066 Class 2, through pattern; color and patterns as selected. Thickness: 1/8 inch (3 mm). Size: 12 x12 inch (300 x 300 mm).
Vinyl Base: ASTM F1861; Type TV - thermoplastic vinyl; top set coved, 4 inch (100 mm) high, 1/8 inch (3 mm) thick, colors as selected. Premolded end stops and external corners, of same material, size, and color as base.
Accessories: Subfloor Filler: White premix latex. Primers and Adhesives: Type recommended by manufacturer.
Moldings and Edge Strips: Same material as flooring, profile to suit flooring material transitions.
Install resilient flooring in accordance with the manufacturer's instructions.

END OF SPECIFICATION